Translation

⁽¹⁾ **EC-Type-Examination Certificate**

(2) Equipment and protective systems intended for use in potentially explosive atmospheres, **Directive 94/9/EC**

(3) Certificate Number TÜV 13 ATEX 129516 X

- (4) for the equipment: Positioner for hydraulic actuators IHP24-I-00000 and IHP24-I-10000 (with Hart Modem)
- (5) of the manufacturer: Val Controls A/S
- (6) Address: Limfjordsvej 3, 6715 Esbjerg Denmark

Order number: 8000426098

Date of issue: 2014-07-09

- (7) The design of this equipment or protective system and any acceptable variation thereto are specified in the schedule to this EC-Type-Examination Certificate and the documents therein referred to.
- (8) The TÜV NORD CERT GmbH, notified body No. 0044 in accordance with Article 9 of the Council Directive of the EC of March 23, 1994 (94/9/EC), certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive. The examination and test results are recorded in the confidential report No. 13 203 129516
- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012

EN 60079-11:2012

EN 60079-26:2007

TUV NORD

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-type-examination certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment or protective system must include the following:

Ex II 1G Ex ia IIC T4/T5/T6 Ga

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the notified body

Mever

Hannover office, Am TÜV 1, 30519 Hannover, Phone +49 (0)511 986 1455, Fax +49 (0)511 986 1590

This certificate may only be reproduced without any change, schedule included. Excerpts or changes shall be allowed by the TÜV NORD CERT GmbH



(13) **SCHEDULE**

(14) EC-Type-Examination Certificate No. TÜV 13 ATEX 129516 X

(15) Description of equipment

IHP24-I is an Intelligent Hydraulic Positioner for hydraulic actuators. From a control room it receives a variable control loop signal 4-20mA. Position is send back to the control room via 4-20mA transmitter loop. Regulating of the position is done by switching on and off DO1, DO2, DO3. The position on the actuator is measured from a position sensor that can be one of the two types:

- Position sensor .. A potentiometer 1Kohm to 20 Kohm - is a simple apparatus.

- Postion Loop ... An ATEX approved intrinsically safe sensor that gives the position back as a 4-20mA signal, powered from the loop current. This sensor could be from a third party supplier and are not covered by this report.

24V power is delivered from a power supply supplied through Zener Barrier modules. The positioner is designed for DIN rail mounting inside cabinet. The IHP24-I has up to 6 Zener Barriers connected simultaneously. Each intrinsically safe circuit are galvanic separated inside IHP24-I.

The specifications for intrinsically safe entity parameters are listed in the manufacturers User Manual and in this certificate.

Recommended barriers are listed in the User Manual. Other barriers fulfilling the intrinsically safe parameters can be used.

Type key:

IHP24-I-00000 and

IHP24-I-10000 (with Hart Modem signals on terminal 1, 2)

Technical data:

recimical uala.	
Terminal 1, 2 (Incoming Control Signal 4-20mA)	Terminal 3, 4 (Transmitter Feedback Signal 4-20mA)
Ui <= 28V	Ui <= 28V
li <= 100mA	li <= 100mA
Pi <= 1.2W	Pi <= 1.2W
Ci <= 100nF	Ci <= 10nF
Li≈0	Li≈0
Terminal 5, 6 (Main Supply 24VDC)	Terminal 8, 9, 10 (Passive Potentiometer 1K – 20Kohm)
Ui <= 28V	- Simple Apparatus
li <= 200mA	Uo <= 6V
Pi <= 1.35W	lo <= 6mA
Ci <= 68nF	Po <= 0.04W
Li = <= 120uH	Ci <= 10uF
	Li≈0
Terminal 11, 12 (Position Transmitter 4-20mA)	Terminal 13, 14 (DO1 - Solenoid 1 Output)
Uo follows the connected barrier to Terminal 5, 6	Uo follows the connected barrier to Terminal 15, 16
lo <= 88mA	Io follows the connected barrier to Terminal 15, 16
Po <= 0.62W	Po follows the connected barrier to Terminal 15, 16
Ci <= 10nF	Ci≈0
Li≈0	Li≈0
Terminal 15, 16 (Solenoid 1 Output Power Supply)	Terminal 17, 18 (DO2 - Solenoid 2 Output)
Ui <= 28V	Uo follows the connected barrier to Terminal 19, 20
li <= 341mA	Io follows the connected barrier to Terminal 19, 20
Pi <= 1.65W	Po follows the connected barrier to Terminal 19, 20
Ci≈0	Ci≈0
Li≈0	Li ≈= 0
Terminal 19, 20 (Solenoid 2 Output Power Supply)	Terminal 21, 22 (DO3 - Solenoid 3 Output)
Ui <= 28V	Uo follows the connected barrier to Terminal 23, 24
li <= 341mA	Io follows the connected barrier to Terminal 23, 24
Pi <= 1.65W	Po follows the connected barrier to Terminal 23, 24



Schedule EC-Type Examination Certificate No. TÜV 13 ATEX 129516 X

Ci≈0	Ci≈0
Li≈0	Li≈0
Terminal 23, 24 (Solenoid 3 Output Power Supply)	
Ui <= 28V	
li <= 34	
1mA	
Pi <= 1.65W	
Ci≈0	
Li ≈ 0	

Permissible range of ambient temperature:

T6 for Ta: from -30°C to +45°C T5 for Ta: from -30°C to +60°C T4 for Ta: from -30°C to +85°C

Ta of Electronic with Display component LCD1: -30°C to +80°C Ta of Electronic without proper Display Functionality: -30°C to +85°C

- (16) Test documents are listed in the test report No. 13 203 129516
- (17) Special conditions for safe use

Warning marking: "WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS"

(18) Essential Health and Safety Requirements

no additional ones